

S a f e t y D a t a S h e e t

Company name : TERAOKA SEISAKUSHO CO., LTD.
Address : 1-4-22 Hiromachi, Shinagawa-ku, Tokyo 140-8711, Japan
Department : Quality Assurance Department
Telephone : 03-3491-0837

Issued : October 1, 2012
Revised : April 24, 2019

1. Product name : Epoxy resin impregnated tape No.5120

2. Hazards identification

GHS Classification : Not applicable to classification standard(because our product is "Article")

Specific hazards : This product contains epoxy resin defined as mutagen.

Bisphenol A type liquid epoxy resin

CAS No.25068-38-6

Bisphenol F type liquid epoxy resin

CAS No.9003-36-5

3. Composition, information on ingredients

Single material or mixture : Mixture material

Component : Polyamide non-woven fabric impregnated with epoxy resin / Release liner

Chemical formula, CAS No. : Not identifiable, because of mixture of several materials

Pollutant Release and Transfer Register Laws (in Japan)

Class 1 Designated Chemical Substances : Not contained

Class 2 Designated Chemical Substances : Not contained

4. Emergency measures

If entered into eyes : Wash with clean running water and consult the doctor.

If affixed to the skin : It is recommended to peel off slowly and then wash with soap and water.

If caused irritation, consult the doctor immediately.

If swallowed : Consult the doctor immediately.

5. Measures against fire

Extinguishing method : According to the common method.

Extinguisher : Water, general use fire extinguisher (powder, bubble, carbonic acid gas)

(Care must be taken not to breathe the gas while burning)

6. Measures against leakage

No leakage.

7. Precautions in handling and storage

Handling : In case of heat-curing, the room shall be well-ventilated since gas could be generated.

Storage : Store under low temperature($5\pm 5^{\circ}\text{C}$) and low humidity.

8. Exposure controls, personal protection

Density to be controlled : Not specified.

Tolerance of density : For Japan Industry Hygienic Institute ... Not specified.

For ACGIH ... Not specified.

Equipment to be provided : Local ventilation and waterworks for washing face, eyes, hands shall be provided.

Protective tool : Not necessary.
